

Anchorage Middletown Fire & EMS

108 Urton Lane  
Louisville, KY 40223  
5022457555



January 9, 2019

Attn: ROBIN BOUGHEY  
MED QUEST COLLEGE  
10400 LINN STATION RD #SUITE 120SUITE 120  
LOUISVILLE, KY 40223

Property Address:  
MED QUEST COLLEGE  
10400 LINN STATION RD SUITE 120  
LOUISVILLE, KY 40223

Re: Initial - EDUCATION INSPECTION on January 09 2019

**EXPLANATION OF ANNUAL FIRE INSPECTION REPORT AND YOUR RESPONSIBILITIES AS BUSINESS OWNER, MANAGER OR DESIGNATED REPRESENTATIVE**

**ORDER TO COMPLY:** As a result of an inspection of these premises, violations of NFPA 1 Fire Code and/or NFPA 101 Life Safety Code have been identified for correction. **Life Safety violation(s)** not corrected **before the re-inspection date listed by the violations**, will result in additional follow up inspection established by The Fire Prevention Bureau of Anchorage Middletown Fire & EMS.

If the violation(s) still has not been corrected after the follow up inspection, the business owner / property owner may be subject to fee(s) pursuant to KRS 227.336. It is the responsibility of the business owner, manager or designated representative to correct all noted violations.

**Failure to immediately correct Imminent Life Safety violations that are deemed *Dangerous to Life Safety* may result in a *Fire Watch* being imposed at the owners' expense and/or closing of the business until violation corrections are made.**

*Note: Records of inspection reports are maintained by the Fire Prevention Bureau of the Anchorage Middletown Fire & EMS and are part of public record requirements of the State of Kentucky. It is possible that information contained in these reports in addition to your failure to correct any noted fire code violations may be used against you in civil and/or criminal proceedings in the event of an incident related to any such violation.*

**Re-inspections may or may not be performed on the date listed below. The date of the re-inspection below is simply the date on which corrections are due. If violation is corrected prior to the re-inspection date, please feel free to email the inspector below.**

Inspector:

Captain Tim Banks

tbanks@amfems.org

502-855-3255

Property Representative:

ROBIN BOUGHEY

**Violation/Information Page(s)**

Inspection Violations

**Have Fire extinguisher inspected and/or recharged**

**13.6.9** Inspection, Maintenance, and Recharging of Portable Fire Extinguishers.

**Inspector Notes: All extinguishers are out of date and need to be inspected and tagged.**

Violation found on  
01/09/2019

Will be rechecked on or after  
02/08/2019

Violation Not  
Repaired