Sprinkler Inspection Certificate

For

1575 - Turner
Development/Medquest/Scott
Gross/Spe
1575 Winchester Rd
Lexington, KY 40505

Tested to NFPA 25 Standards

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Date Apr 1, 2020

> Building: 1575 - Turner Development/Medquest/Scott Gross/Spe Contact: Kim Davis Title: Vice President

Company: Amteck

Contact: Brent Carver Title: Project Manager

Executive Summary

Generated by: BuildingReports.com

Building Information

Building: 1575 - Turner

Development/Medquest/Scott Gross/Spe

Address: 1575 Winchester Rd

Address:

City/State/Zip: Lexington, KY 40505

Country: United States of America

Inspection Performed By

Company: Amteck

Address: 1387 E New Circle Rd

Address:

City/State/Zip: Lexington, KY 40505

Country: United States of America

Contact: Kim Davis

Phone: 859-977-0820

Fax:

Mobile:

Email:

Inspector: Brent Carver

Phone: 8592559546

Fax:

Mobile:

Email: bcarver@amteck.com

Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Device	4	20.00%	4	100.00%	4	100.00%	0	0%
Alarm	4	20.00%	4	100.00%	4	100.00%	0	0%
Valve	8	40.00%	8	100.00%	8	100.00%	0	0%
Hose	2	10.00%	2	100.00%	2	100.00%	0	0%
Sprinkler	2	10.00%	2	100.00%	2	100.00%	0	0%
Totals	20	100%	20	100.00	20	100.00	0	0%

Certification

Company: Amteck

Building: 1575 - Turner

Development/Medquest/Scott Gross/Spe

Inspector: Brent Carver

Contact: Kim Davis

Signed: Signed:

Brent Carver Certifications	
Certification Type	Number
Ansul R-102 System Certified	RD-0102
BGCCPA Certification	
Indiana State Certification - Backflow Device Tester	BF20-6849
Kentucky State Fire Alarm Inspector	FAR-1694
Kentucky State Sprinkler Inspector	SSR-0863

Inspection & Testing

Generated by: BuildingReports.com

Building: 1575 - Turner Development/Medquest/Scott Gross/Spe

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Device Type	Location	Service	Time	Date			
Passed							
MED QUEST							
Tamper Switch	Parking Back Parking Lot	Annual	9:53:11 AM	04/01/2020			
Waterflow Switch	1 st	Annual	9:47:18 AM	04/01/2020			
Drain	1 st	Annual	9:49:16 AM	04/01/2020			
Gauge	1 st	Annual	9:49:49 AM	04/01/2020			
Fire Dep't Connection	1 st	Annual	9:48:35 AM	04/01/2020			
Sprinkler Box	1 st	Annual	9:50:00 AM	04/01/2020			
Check Valve	1 st	Annual	9:48:08 AM	04/01/2020			
Check Valve	1 st	Annual	9:49:29 AM	04/01/2020			
Inspector's Test	1 st	Annual	9:50:11 AM	04/01/2020			
Post Indicator Valve	Parking Back Parking Lot	Annual	9:52:57 AM	04/01/2020			
SPECTRUM							
Tamper Switch	Parking Back Parking Lot	Annual	9:36:50 AM	04/01/2020			
Waterflow Switch	lst	Annual	9:33:06 AM	04/01/2020			
Drain	1 st	Annual	9:30:17 AM	04/01/2020			
Gauge	1 st	Annual	9:25:43 AM	04/01/2020			
Fire Dep't Connection	1 st	Annual	9:34:21 AM	04/01/2020			
Sprinkler Box	1 st	Annual	9:28:54 AM	04/01/2020			
Check Valve	1 st	Annual	9:38:38 AM	04/01/2020			
Check Valve	1 st	Annual	9:38:56 AM	04/01/2020			
Inspector's Test	1 st	Annual	9:37:55 AM	04/01/2020			
Post Indicator Valve	Parking Back Parking Lot	Annual	9:36:36 AM	04/01/2020			

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: 1575 - Turner Development/Medquest/Scott Gross/Spe

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Type	De Category			% of Inventory	Quantity	
Gauge		Device		10.00%	2	
Sprinkler Box	Sprinkler			10.00%	2	
Drain		Device		10.00%	2	
Waterflow Switch		Alarm		10.00%	2	
Fire Dep't Connection		Hose		10.00%	2	
Post Indicator Valve		Valve		10.00%	2	
Tamper Switch		Alarm		10.00%	2	
Inspector's Test		Valve 10.00%			2	
Check Valve		Valve		20.00%	4	
	Qt					
Device Type	У	Model #	Type	Description	Install Date	
		Nev	v (under	90 days)		
MED QUEST						
Check Valve	2		Flanged		04/01/2020	
Drain	1		Main		04/01/2020	
Fire Dep't Connection	1		Wall		04/01/2020	
Gauge	1		System Pro	essur e	04/01/2020	
Inspector's Test	1		·		04/01/2020	
Post Indicator Valve	1		Ground		04/01/2020	
Sprinkler Box	1				04/01/2020	
Tamper Switch	1		OS&Y	Supervisory	04/01/2020	
Waterflow Switch	1		Vane	Alarm	04/01/2020	
SPECTRUM						
Check Valve	2		Flanged		04/01/2020	
Drain	1		Main		04/01/2020	
Fire Dep't Connection	1		Wall		04/01/2020	
Gauge	1		System Pr	essure	04/01/2020	
Inspector's Test	1		-		04/01/2020	
Post Indicator Valve	1		Ground		04/01/2020	
Sprinkler Box	1				04/01/2020	
Tamper Switch	1		Vane	Supervisory	04/01/2020	
Waterflow Switch	1		Vane	Alarm	04/01/2020	